

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you

have a right to know what happened, what you should do, and what we are doing to correct this situation.

Jefferson Co Cons RWD #1 Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for the indicated time

period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes

(TTHM). The standard or MCL for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each

sampling location for the past 12 months. The level of total trihalomethanes averaged at our system's locations was the

following:

Locational Running Annual Average with Sample Location

0.109 & 0.123 MG/L - TURNER SCHOOL 22069 STATE HWY 32

Twelve-month time period July 2021 through September 2022

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant

or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care

providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately. However, some

people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with

their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

We are working diligently to move more well water and not rely on water purchased from the City of Waurika.

This violation only occurred at our testing site on Hwy 32.

PWS Number OK3003401 Case Number: CO 22-028 This notice is being sent to you by Jefferson Co Cons RWD #1